



Test Verification of Conformity

Certificate No.: CTEE22040007

Date: Apr. 01, 2022

In accordance with the following Applicable Directives:

2014/30/EU

Electromagnetic Compatibility

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

EN 61326-1: 2013 EN 61326-2-3: 2013

EN 55011:2016+A1:2017

EN 55032:2015+AC:2016+A11:2020

EN 61000-3-3: 2013+A1: 2019

EN 61000-6-4: 2007+A1: 2011

EN IEC 61000-3-2: 2019

The test results are traceable to the international or national standards.

Applicant: CET Electric Technology Inc.

8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen, Guangdong, P.R.China 518040

Manufacturer: CET Electric Technology Inc.

8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen, Guangdong, P.R.China 518040

EUT Name: Advanced Power Quality Analyzer

Model number: iMeter 7A-A5925CAE

Listed Model(s): See Attachment Page

Laboratory: Shenzhen Huatongwei International Inspection Co., Ltd.

1/F, Bldg 3 and Bldg 9, Hongfa Hi-tech Industrial Park, Genyu Road, Tianliao, Gongming, Shenzhen, Guangdong, China

Tel: 86-755-26715499

E-mail: cs@szhtw.com.cn

Website: Http://www.szhtw.com.cn



Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

The CE mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an EC Directive of Conformity and compliance with all relevant EC Directive.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTEE22040007

Date: Apr. 01, 2022

Listed Model(s): iMeter 7A-XY92ZOAQ

(

“X” in the model name may represent A or B where

- A means IEC 61000-4-30 Ed. 3 Class A Compliance
- B means IEC 61000-4-30 Ed. 3 Class A Compliance with 2kHz-150kHz C. E. Measurements

“Y” in the model name may represent 1, 5, SCCT, SCCTA or SCCPA where

- 1 means 1A input
- 5 means 5A input
- SCCT means SCCT Option for use with 100A/200A/400A/800A/1600A to 40mA SCCTs
- SCCTA means SCCT Option for use with 5A/2mA SCCTs
- SCCPA means SCCP Option for use with CT Clamps with max. 500mV output

“Z” in the model name may represent 5 or 6 where

- 5 means 50Hz
- 6 means 60Hz

“O” in the model name may represent A, B, C or D where

- A means 4xDI + 3xDO
- B means 4xDI + 1xDO + 2xSS Pulse Outputs
- C means 8xDI + 5xDO + 2xAI
- D means 8xDI + 5xDO + 2xRTD Inputs

“Q” in the model name may represent C or E where

- C means Chinese
- E means English

)