



230020349797



中国认可
国际互认
检测
TESTING
CNAS L0730



SOUTH CHINA NATIONAL CENTER OF METROLOGY

GUANGDONG INSTITUTE OF METROLOGY

TEST REPORT

No. XNZ202401106

Name of Sample: Single-Phase Multifunction Meter

Model / Type: PMC-230-BC35AE
240V 5(63)A 50/60Hz

Sample Number: 3307098716 3307098718 3307098719
3307098714 3307098720 3307098722

Applicant: CET Electric Technology Inc.

Manufacturer: CET Electric Technology Inc.

Test Type: Commission

Date Issued: 2024-09-26



(1) Basic Information

Name of Sample	Single-Phase Multifunction Meter	Trade Mark	—
Model / Type	PMC-230-BC35AE 240V 5(63)A 50/60Hz	Class	Cl. 1(Active)
Sample No.	3307098716 3307098718 3307098719 3307098714 3307098720 3307098722	Sample quantity	6
Applicant	CET Electric Technology Inc.		
Address	8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen, Guangdong, P.R.China 518040		
Manufacturer	CET Electric Technology Inc.		
Test Site	Environment Lab of Dongguan Branch		
Test Conditions	Temperature: (25~30) °C Humidity: (50~70) %RH		
Date Received	May 27, 2024	Commission No.	WT20241085
Test Date	May 27, 2024~Sep. 25,2024	Test Type	Commission
Test Item	See test result		
Test Standard	IEC 62052-31:2015 Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 31: Product safety requirements and tests AS 62052.31:2017+A1:2021 Electricity metering equipment (AC) - General requirements, tests and test conditions Part 31: Product safety requirements and tests		
Conclusion	PASS		
Remarks	—		

Tested by: 王涵涛

Checked by: 徐煜彬

Approved by: 司登锦