

CERTIFICATE OF COMPLIANCE

Certificate Number 2020-07-17-E510251
Report Reference E510251-D1000-1/A0/C1-UL
Issue Date 2020-07-17

Issued to: CET Electric Technology Inc
Applicant Company: 8/F Westside Building 201 Terra Industrial & Tradepark Che
Gong Miao
Shenzhen, 518040 China

Listed Company: Same as Applicant

**This is to certify that
representative samples of**

The equipments are intelligent multifunction meter, which used as a built-in equipment to measure and monitor the 1 or 3 phase voltage, current, frequency and power measurements.

PMC-53A, followed by -1, -2, -3, -A or -B, followed by 1 or 5, followed by 9, followed by 2, followed by 5, followed by E, followed by -A1, -A2 or blank, followed by -B1, -B2, -B3, -B4 or blank.

PMC-53A-E, followed by 1, 4 or 5, followed by 9, followed by 2, followed by 5, followed by A or B, followed by X or A, followed by E.

PMC-53M-A, followed by -5, followed by 9, followed by 2, followed by 5, followed by X or B, followed by A, followed by E.

PMC-53M-E, followed by -5, followed by 9, followed by 2, followed by 5, followed by X or B, followed by A, followed by E.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 61010-1, 3rd Edition, May 11, 2012, Revised July 19 2019, CAN/CSA-C22.2 No. 61010-1-12, 3rd Edition, Amendment 1:2018, Revision dated November 21 2018

Additional Standards: UL 61010-2-030, Second Edition, CSA C22.2 NO. 61010-2-030:18, Second Edition
UL 61010-2-201, Second Edition, CSA C22.2 No. 61010-2-201, Second Edition, only sub-clauses 4.4.1.101 are used for evaluating pulse output resistive load overload test



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services, UL LLC
Joseph Hosey, General Manager, Director of Sales – Canada, UNDERWRITERS LABORATORIES OF CANADA INC.



Helena Y. Wolf, Director, Global Market Access Operations, UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative www.ul.com/contactus




Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information.

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services, UL LLC
Joseph Hosey, General Manager, Director of Sales – Canada, UNDERWRITERS LABORATORIES OF CANADA INC.


Helena Y. Wolf, Director, Global Market Access Operations, UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative www.ul.com/contactus

